


Simplified Combustion Calculations Combustion Control Systems (CCS)

Introduction

The sizing of various boiler control field devices requires fluid flow rate information that may not be available from vendors or owners. Basic thermodynamic energy balance calculations can be used for determining these flows and is the subject of this paper.

Boiler Energy Balance



Input / Output Efficiency

The efficiency is defined as the amount of energy gained converting the feedwater to steam (neglecting Blow Down), the output, divided by the amount of fuel energy used for this conversion, the input. This allows the calculation of heat input for known heat output by ($In = Out / Eff$). See Table 1 below:

Boiler Rating:	50,000	LB/HR	100	PSIG	Sat.
Steam:	1,190.20 BTU/LB	from Steam Tables	100	PSIG	Sat.
FW:	198.7 BTU/LB	from Steam Tables	150	PSIG	230 DEG F
Gain:	991.50 BTU/LB	Note: 1000 BTU/LB is commonly assumed for Saturated Steam			
Output:	50,000	X	991.50	=	49.575 MMBTU/HR
Efficiency:	80%	Assumed (Typical)			
Input:	49.575	/	80%	=	61.969 MMBTU/HR of fuel used

Table 1 Determine Fuel Flow in Terms of Heat

Fuel Properties

Once the fuel heat flow is determined, it may be converted to mass or volumetric flows given the fuel type. Normal design values for common fuels are given in Table 2 below. These values are used in Vendor sizing programs for flow elements. Note that actual values for fuel properties should be used if known.

Property	Natural Gas		No. 2 Oil		No. 6 Oil	
High Heat Value, Mass	23,200	BTU/LB	19,500	BTU/LB	18,600	BTU/LB
High Heat Value, Vol	1,000	BTU/SCF	139,000	BTU/GAL	150,000	BTU/GAL
Specific Gravity	0.6	at 14.7a, 60l	0.85		0.97	
Density (14.7 Psia, 60 F)	0.0458	LB/FT3	53.4	LB/FT3	60.7	LB/FT3
Viscosity	0.013	cP at 60F	6.7	cP at 100F	32	cP at 200F
Stoichiometric Air / MMBTU	718	Lb	727	Lb	740	Lb
Typical Excess Air	10%		15%		15%	
O2 at Typical Excess Air	1.7%		2.7%		2.7%	

Table 2 Fuel Properties

Flow Calculations

Using the example given in Table 1, the flows are calculated as follows in Table 3.

Boiler Rating:	50,000	LB/HR	100	PSIG	Sat.
Fuel Heat Input:	61.969	MMBTU/HR of fuel used			
Gas Flow:	61.969	/	23,200	=	2,671 LB/HR
	61.969	/	1,000	=	61,969 SCFH
Stoic Air	61.969	X	718	=	44,494 LB/HR
at 10%Air	44,494	X	1.1	=	48,943 LB/HR
Oil Flow:	61.969	/	19,500	=	3,178 LB/HR
	61.969	/	139,000	=	446 GPH
Stoic Air	61.969	X	727	=	45,051 LB/HR
at 15%Air	45,051	X	1.15	=	51,809 LB/HR

Table 3 Flow Calculations

Summary

The above fuel properties and procedures allow flow calculations of sufficient accuracy to size flow elements, in the absence of more detailed information, for normal boiler fuels.